

CROTON FALLS

WELL COMPLETION REPORT
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

6217

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.


REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41 21 01 73 43 33

P975

OWNER	NAME MICHANTH HOMES		ADDRESS WOOD STREET, RD #4, MAHOPAC, NEW YORK			
LOCATION OF WELL	OVERLOOK DRIVE, TEAKETTLE SPOUT LAKE, MAHOPAC, NEW YORK					
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	<i>720 5</i>	
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY	<input type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
CASING DETAILS	LENGTH (feet) 50	DIAMETER (inches) six	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS five	G.P.M. five	YIELD (G.P.M.) 5 GPM
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 41 ft.			DURING YIELD TEST (feet) <i>41</i>		Depth of Completed Well in feet below land surface: 285 ft.
SCREEN DETAILS	MAKE	LENGTH OPEN TO AQUIFER (feet)				
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	to FEET	
0	40	Drilling in overburden-clay and boulders Hit solid rock at 40 ft.
40	50	Drilling in rock-setting casing-grouted
50	285	Drilling in rock - granite
If yield was tested at different depths during drilling, list below		
FEET	GALLONS PER MINUTE	



DATE WELL COMPLETED 10/2/73	DATE OF REPORT 10/11/73	WELL DRILLER (Signature) <i>Malcolm T. Beal</i>	P. F. BEAL & SONS, INC. <i>Inc</i>
--------------------------------	----------------------------	--	---------------------------------------