

CLOTON FALLS

6223

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P 978

41 22 09 73 42 12

OWNER	NAME ANTTI HAIKOLA		ADDRESS R.F.D. #2, Overlook Dr., Mahopac, N.Y.			
LOCATION OF WELL	(No. & Street) Pigott Road,		(Town) Mahopac, New York		(Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL	<i>640 5</i>	
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)		
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)		
CASING DETAILS	LENGTH (feet) 15	DIAMETER (inches) 6	WEIGHT PER FOOT 17	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	WAS CASING GRouted? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 2	G.P.M.	YIELD (G.P.M.) 3
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) 105		DURING YIELD TEST (feet) 500		Depth of Completed Well in feet below Land surface: 500	
SCREEN DETAILS	MAKE					LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches) FROM (feet) TO (feet)	

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	TO FEET	
0	2	Soft silt.
2	500	Hard granite.

Sketch exact location of well with distances, to at least two permanent landmarks.

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 1/24/72	DATE OF REPORT 2/4/72	WELL DRILLER (Signature) <i>Robert M Mill</i> , President
--------------------------------	--------------------------	--

MILL DRILLING, INC.