41 25 08 73 4410 PUTNAM COUNTY DEPARTMENT OF HEALTH
LAKE CARMEL Division of Environmental Health Services
COUNTY OFFICE BUILDING · CARMEL, NEW YORK

MPLETION REPORT

C230

report is to be completed by well driller and submitted to County Health Department together with laboratory report of sis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P982

N	NAME Larry Salonpuro (No. & Street)	ADDRESS PO Box 107 (Town) Mahopac, New York	Mahopac, New York (Lot Number) #26
	Rick Lane, Dixon Lake		

ED

[X] DOMESTIC [ ] BUSINESS ESTABLISHMENT [ ] FARM [ ] TEST WELL 750 S

[ ] PUBLIC SUPPLY [ ] INDUSTRIAL [ ] AIR CONDITIONING [ ] OTHER (Specify)

NO ENT

[X] ROTARY [ ] COMPRESSED AIR PERCUSSION [ ] CABLE PERCUSSION [ ] OTHER (Specify)

NO LS	LENGTH (feet)	DIAMETER (inches)	WEIGHT PER FOOT	[X] THREADED [ ] WELDED	DRIVE SHOE [X] YES [ ] NO	WAS CASING GROUTED [X] YES [ ] NO
	20'	6"	19 lbs			

D T	[ ] BAILED	[ ] PUMPED	[X] COMPRESSED AIR	HOURS 6	G.P.M. 6	YIELD (G.P.M.) 8 gpm

ER EL	MEASURE FROM LAND SURFACE—STATIC (Specify feet)	DURING YIELD TEST (feet)	Depth of Completed Well in feet below land surface: 135'	LENGTH OPEN TO AQUIFER (feet)
	25'			

EEN ARS	MAKE	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet)	TO (feet)

Sketch exact location of well with distances, to at least two permanent landmarks.

OM LAND SURFACE AT TO FEET	FORMATION DESCRIPTION
3	Drilling inoverburden-clay and boulders
	Hit solid rock at 3 feet
20	Drilling in solid rock=set casing-grouted
135	Drilling in rock-granite and quartzite

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

TE WELL COMPLETED	DATE OF REPORT	WELL DRILLER (Signature)
6/30/8	8/25/75	P. F. BEAL & SONS, INC.