C248

Westchester County Department of Health
Division of Environmental Sanitation

Mohegan

P 989

WELL COMPLETION REPORT

This report is to be completed by well driller and submitted to Health Department, together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality, before certificate of construction compliance is issued.

510' L'

Well construction to be in accordance with Bulletin SD-62
"RULES & REGULATIONS RELATING TO INDIVIDUAL WATER SUPPLIES"

LOCATION: MUNICIPALITY Mohegan SECTION 1 ~~BLOCK~~ Map 1346 LOT #3

WELL OWNER: Bob Cox Enterprises RFD #4 Mohegan NY
Name Street Address City and Town
Stillwater Rd.

WELL DRILLER: WRAGG BROS. WELL DRILLING CORP. ROUTE 7, WILTON, CONN.
Name Street Address City and Town

CASING DETAILS		YIELD TEST		WATER LEVEL (measure from land surface)		SCREEN DETAILS	
Length: 130	Feet	X Bailed or Pumped	6 Hours	Static: 15	Feet	Make: N/A	
Diameter: 6	Inches	Yield: 15	G.P.M.	When Bailed or Pumped 285	Feet	Length N/A	Ft. Slot Size
Kind: STEEL						Diameter N/A	In.

TOTAL DEPTH OF WELL 285 FEET

WELL LOG

Depth From Ground Surface	Give description of formations penetrated, such as: peat, silt, sand, gravel, clay, hardpan, shale, sandstone, granite, etc. Include size of gravel (diam and sand (fine, medium, coarse), color of material, structure (Loose, packed, cemented, soft, hard). For example: 0 ft. to 27 ft. fine, packed, yellow sa 27 ft. to 13½ ft. grey granite.
0 Ft. to 120 Ft.	CLAY.
120 Ft. to 285 Ft.	DARK GREY AND LIGHT GREY ROCK.
Ft. to Ft.	
Ft. to Ft.	
Ft. to Ft.	
Ft. to Ft.	
Ft. to Ft.	
Ft. to Ft.	

Date Well Was Completed 6/25/77 Date of Report 6/27/77

Well Driller Bruce W. Wragg WRAGG BROS.