

6249

41 20 59 73 45 52

Hohegan

Westchester County Department of Health
Division of Environmental Sanitation

WELL COMPLETION REPORT

P 990

This report is to be completed by well driller and submitted to Health Department, together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality, before certificate of construction compliance is issued.

740 H

Well construction to be in accordance with Bulletin SD-62
"RULES & REGULATIONS RELATING TO INDIVIDUAL WATER SUPPLIES"

LOCATION: MUNICIPALITY PUTNAM COUNTY SECTION _____ BLOCK _____ LOT _____

WELL OWNER: Brendan Harris Summit Rd. MAHOPAC N.Y.
Name Street Address City and Town

WELL DRILLER: JAMES TORLICK MAPLE AVE ARMONK N.Y.
Name Street Address City and Town

CASING DETAILS		YIELD TEST		WATER LEVEL		SCREEN DETAILS	
Length:	<u>12</u> Feet	Bailed or <input checked="" type="checkbox"/> Pumped	<u>6</u> Hours	Static:	<u>4.0</u> Feet	Make:	
Diameter:	<u>6</u> Inches	Yield:	<u>6</u> G.P.M.	When Bailed or Pumped	<u>30.0</u> Feet	Length	Ft. Slot Size
Kind:	<u>STEEL</u>					Diameter	In.

TOTAL DEPTH OF WELL 385 FEET

WELL LOG

Depth From Ground Surface	Give description of formations penetrated, such as: peat, silt, sand, gravel, clay, hardpan, shale, sandstone, granite, etc. Include size of gravel (diameter) and sand (fine, medium, coarse), color of material, structure (Loose, packed, cemented, soft, hard). For example: 0 ft. to 27 ft. fine, packed, yellow sand; 27 ft. to 134 ft. gray granite.
<u>0 Ft. to 1 Ft.</u>	<u>TOP SOIL</u>
<u>1 Ft. to 120 Ft.</u>	<u>GREEN ROCK</u>
<u>120 Ft. to 250 Ft.</u>	<u>GRAY ROCK</u>
<u>250 Ft. to 385 Ft.</u>	<u>GREEN ROCK</u>
Ft. to Ft.	

Date Well Was Completed Feb 11, 1972 Date of Report April 6, 1972

Well Driller James Torlick Signature