

WELL COMPLETION REPORT

3/71 C30

LOTON FALLS

PUTNAM COUNTY DEPARTMENT OF HEALTH

Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P999


41 21 09 73 43 21

OWNER	NAME HONKOLA BUILDERS, INC.		ADDRESS P.O. Box 58, Mahopac, New York	
LOCATION OF WELL	(No. & Street) Brookside Road		(Town) Mahopac, New York	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC	<input type="checkbox"/> BUSINESS ESTABLISHMENT	<input type="checkbox"/> FARM	<input type="checkbox"/> TEST WELL
	<input type="checkbox"/> PUBLIC SUPPLY	<input type="checkbox"/> INDUSTRIAL	<input type="checkbox"/> AIR CONDITIONING	<input type="checkbox"/> OTHER (Specify)
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY	<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION	<input type="checkbox"/> CABLE PERCUSSION	<input type="checkbox"/> OTHER (Specify)
	CASING DETAILS	LENGTH (feet) 40	DIAMETER (Inches) 6	WEIGHT PER FOOT 17
YIELD TEST	<input checked="" type="checkbox"/> THREADED		<input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
	<input type="checkbox"/> BAILED	<input type="checkbox"/> PUMPED	<input checked="" type="checkbox"/> COMPRESSED AIR	HOURS 2
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) 25		DURING YIELD TEST (feet) 155	Depth of Completed Well in feet below land surface: 155
	MAKE			LENGTH OPEN TO AQUIFER (feet)
SCREEN DETAILS	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (Inches):
			GRAVEL SIZE (Inches)	FROM (feet) TO (feet)

620 C

DEPTH FROM LAND SURFACE		FORMATION DESCRIPTION
FEET	to FEET	
0	32	Hardpan and boulders.
32	34	Weathered ledge.
34	155	Hard granite.
If yield was tested at different depths during drilling, list below		
FEET	GALLONS PER MINUTE	

Sketch exact location of well with distances, to at least two permanent landmarks.



Brookside Road

DATE WELL COMPLETED 5/27/72	DATE OF REPORT 5/30/72	WELL DRILLER (Signature) <i>[Signature]</i>	President
--------------------------------	---------------------------	--	-----------

WELL DRILLING, INC.